Certificate

Product Safety

- with the right to S marking

Reference No / Referensnr. 300973

Fan for mounting in ventilating duct

Type designation / Typbeteckning	CE 140 L.., CE 140 M.., CE 140 S..
Manufacturer / Certifikatsinnehavare	**Systemair AB** **Industrivägen 3** **SE-739 30 Skinnskatteberg** **SWEDEN**
The product complies with the standard(s) / Produkt uppfyller standard	EN 60335-1:1994 and A1+A2+A11-A16 EN 60335-2-80:1997
Date of expiry / Giltigt längst t o m	31 December 2013
LVD Information	*The product satisfies the provisions for CE marking according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.*

Terms in SEMKO's Agreement on certification. Additional information in Appendix.

Certification Body / Certifieringsorgan SEMKO AB, Product Certification

Place / Ort Kista - Stockholm

Signed / Underskrift

Alve Nilsson

Date / Datum 29 April 2003

ITS Intertek Testing Services
ETL SEMKO

SEMKO

Appendix

Reference No / Referensnr. 300973

Technical data /Tekniska data

Type designation / Typbeteckning	CE 140 L..
Rated Voltage (V) / Märkspänning	230
Rated Current (A) / Märkström	-
Rated Power (W) / Märkeffekt	170
Frequency (Hz)/ Frekvens	50
Class / Skyddsklass	I

Type designation / Typbeteckning	CE 140 M..
Rated Voltage (V) / Märkspänning	230
Rated Current (A) / Märkström	-
Rated Power (W) / Märkeffekt	125
Frequency (Hz)/ Frekvens	50
Class / Skyddsklass	I

Type designation / Typbeteckning	CE 140 S..
Rated Voltage (V) / Märkspänning	230
Rated Current (A) / Märkström	-
Rated Power (W) / Märkeffekt	100
Frequency (Hz)/ Frekvens	50
Class / Skyddsklass	I

Manufacturing site(s) / Tillverkningsställe(n)

Systemair AB
Industrivägen 3
SE-739 30 Skinnskatteberg
SWEDEN

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the products according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.

Kista/Stockholm
29 April 2003

Alve Nilsson

VAT No. SE556024069901, Registered Office, Stockholm, Sweden 8111