

Certificate




for European Product Safety

Reference No. 706987

Roof type fan

Type designation	TFS*****
Certificate holder	Systemair AB Industrivägen 3 739 30 Skinnskatteberg SWEDEN
The product complies with the standard(s)	EN 60335-1:2002+A11+A1+A12+A2 EN 60335-2-80:2003+A1 EN 50366:2003+A1
Date of expiry	26 May 2013
EU-direktivsinformation	Produkten uppfyller kraven för CE-märkning enligt lågspänningsdirektivet 2006/95/EG.

Additional information in Appendix.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
Signed	 Erik Wallerfelt	Date	26 May 2008 Page 1 of 3

This certificate is issued in accordance with the terms and conditions set out in the Appendix.



Appendix

Reference No. 706987

Technical data

Type designation	TFSR 125 M, TFSK 125 M
Rated voltage (V)	230
Rated power (W)	25
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	TFSR 125 XL, TFSK 125 XL
Rated voltage (V)	230
Rated power (W)	53
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	TFSR 160, TFSK 160
Rated voltage (V)	230
Rated power (W)	60
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	TFSR 200, TFSK 200
Rated voltage (V)	230
Rated power (W)	108
Frequency (Hz)	50
Class	I
IP-Class	44

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.



Appendix

Reference No. 706987

Type designation	TFSR 315 M, TFSK 315 M
Rated voltage (V)	230
Rated power (W)	211
Frequency (Hz)	50
Class	I
IP-Class	44

Type designation	TFSR 315 L, TFSK 315 L
Rated voltage (V)	230
Rated power (W)	308
Frequency (Hz)	50
Class	I
IP-Class	44

Manufacturing site(s) Systemair AB
 Industrivägen 3
 739 30 Skinnskatteberg
 SWEDEN

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 2006/95/EC.

The product is not evaluated with respect to countries with a mains voltage of 230 V + 10 %.

Safety related parts of the user instructions shall be written in a language acceptable to the country where the product is to be used.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed


Erik Wallerfelt

Date 26 May 2008

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.