

Certificate



for European Product Safety

Reference No. 514610


Fan for mounting in ventilating duct

Type designation	KVK....
Certificate holder	Systemair AB Industrivägen 3 739 30 Skinnskatteberg SWEDEN
The product complies with the standard(s)	EN 60335-1:2002+A11+A1 EN 60335-2-80:2003+A1 EN 50366:2003
Date of expiry	10 November 2010
EU Directive information	The product satisfies the provisions for CE marking according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.

Terms in Intertek Semko's Agreement on certification. Additional information in Appendix.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
--------------------	--	-------	-------------------

Signed


Erik Wallerfelt

Date 10 November 2005



Appendix

Reference No. 514610

Technical data

Type designation / Typbeteckning	KVK....
Rated Voltage (V) / Märkspänning	230
Rated Power (W) / Märkeffekt	680, 670, 650, 340, 310, 180, 85, 45
Class / Skyddsklass	I
IP-Class / IP-Klass	44

Manufacturing site(s) Systemair AB
Industrivägen 3
739 30 Skinnskatteberg
SWEDEN

The product is not evaluated with respect to countries with a mains voltage of 230 V + 10 %.

Safety related parts of the user instructions shall be written in a language acceptable to the country where the product is to be used.


This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the products according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.

Certification Body

Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed


Erik Wallerfelt

Date 10 November 2005